



- NOTE:
1. Any porch or carport shall not be attached to any manufactured home without engineering design.
  2. This handout is a guide to minimum design requirements. Any design other than the requirements in this handout shall be by an engineer.
  3. The only attachment approved to a manufactured home is the roof covering. No structural attachment is allowed.
  4. The term "approved", is a method or material approved by the building official.
  5. All areas with an asterisk (\*) shall be filled in with proposed design.
  6. The roof shall not attach to existing fascia or rafter tails.

Size	Spacing	Maximum Span
2 x 4	12"	9' - 10"
	16"	8' - 11"
	24"	7' - 10"
2 x 6	12"	15' - 6"
	16"	14' - 1"
	24"	11' - 9"
2 x 8	12"	20' - 5"
	16"	18' - 2"
	24"	14' - 10"
2 x 10	12"	25' - 8"
	16"	22' - 3"
	24"	18' - 2"

Post Spacing	Roof Span							
	8'	9'	10'	11'	12'	13'	14'	15'
8'	4 x 6	4 x 6	4 x 6	4 x 6	4 x 6	4 x 6	4 x 6	4 x 6
9'	4 x 6	4 x 6	4 x 6	4 x 6	4 x 6	4 x 8	4 x 8	4 x 8
10'	4 x 6	4 x 6	4 x 6	4 x 8	4 x 8	4 x 8	4 x 8	4 x 8
11'	4 x 6	4 x 8	4 x 8	4 x 8	4 x 8	4 x 8	4 x 8	4 x 10
12'	4 x 8	4 x 8	4 x 8	4 x 8	4 x 8	4 x 10	4 x 10	4 x 10
13'	4 x 8	4 x 8	4 x 8	4 x 10				
14'	4 x 8	4 x 10	4 x 10	4 x 10	4 x 10	4 x 12	4 x 12	4 x 12
15'	4 x 10	4 x 10	4 x 10	4 x 12				

Option using?: #1  #2

**City of Caldwell**  
Department of Building Safety

# City of Caldwell

TITLE  
**TYPICAL PORCH/CARPORT SECTION**

SIZE	CAGE CODE	DWG NO	12-06	REV
SCALE		NTS	SHEET	1