



CITY OF
Caldwell, Idaho

JAROM WAGONER

Mayor

208.455.3011
(f) 208.455.3003

City Hall

205 South 6th Ave.
Caldwell, Idaho 83605

Post Office Box

P.O. Box 1179
Caldwell, Idaho 83606

For a list of the City
Council members, visit:

Website

www.cityofcaldwell.org

Heidi Caye
Compliance Officer

Idaho Department of Environmental Quality
Boise Regional Office
1445 North Orchard Street
Boise, Idaho 83706

September 18th, 2025

Re: SSO – 2119 Stocktrail rd. Caldwell, Idaho

The purpose of this letter is to notify IDEQ of a non-compliance incident that happened at Stocktrail Rd, Caldwell, ID on November 10, 2025.

The cities staff went to our 21st St. lift station to replace a gasket on the pumps 6" discharge hose. In the processes of changing the gasket, the 6" discharge hose was accidentally dropped, which resulted in approximately 25 gallons of rare sewer spilling out on to the ground. The raw sewer was contained to a small area on the sidewalk and roadway. No sewage made it to the waters of the U.S.

The contaminated area was treated with lime and cleaned up the next day.

A call was made to the 24-hr. hotline at approximately 4:00pm Monday, November 10th, 2025. Please feel free to contact us if you have any questions regarding this situation. Thank you for your time and attention to this matter.

Sincerely,

Andrew Abercrombie
Wastewater Assistant Superintendent



"The Treasure of the Valley"