

## DMR Copy of Record

Form Approved OMB No. 2040-0004 expires on 07/31/2026

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's control for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit																			
Permit #:	ID0021504			Permittee:	CALDWELL, CITY OF			Facility:	CALDWELL, CITY OF - CALDWELL WWTP										
Major:	Yes			Permittee Address:	621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605			Facility Location:	208 JOHNSON LANE CALDWELL, ID 83605										
Permitted Feature:	001 External Outfall			Discharge:	001-A Boise River														
Report Dates & Status																			
Monitoring Period:	From 11/01/25 to 11/30/25			DMR Due Date:	12/20/25			Status:	NetDMR Validated										
Considerations for Form Completion																			
P=Effluent, See Table 1, Note 10 for samples to be collected on the same day; Q=Effluent, full narrative description in Permit Part I.B.3.; R=Effluent, Table 1, note 7. Report Mo Inst Max, Max Daily Avg, 7 Day Running Avg of Daily Inst Max																			
Principal Executive Officer																			
First Name:	David			Title:	WW Superintendent			Telephone:	208-477-4605										
Last Name:	Harmon																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Parameter Monitoring Location Season # Param. NODI																			
Code	Name	Monitoring Location	Season #	Param. NODI	Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00010	Temperature, water deg. centigrade	R - See Comments	0	--	Sample					=	20.6	=	20.2	=	20.7	04 - deg C		99/99 - Continuous	RC - Recorder (auto)
					Permit Req.						Req Mon MX DA AV		Req Mon 7D AV		Req Mon INST MAX	04 - deg C	0	99/99 - Continuous	RC - Recorder (auto)
00094	Conductivity	P - See Comments	0	--	Sample					=	845.5	=	883.0		11 - umho/cm		01/30 - Monthly	24 - 24 Hour Composite	
					Permit Req.						Req Mon MO AVG		Req Mon DAILY MX		11 - umho/cm		01/30 - Monthly	24 - 24 Hour Composite	
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	312.3	=	274.6	=	26 - lb/d	=	4.3	=	5.3	19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite	
					Permit Req.						2127.0 MO AVG	<=	3190.0 WKLY AVG	26 - lb/d				01/07 - Weekly	24 - 24 Hour Composite
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample					=	222.2				19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite		
					Permit Req.						Req Mon MO AVG				19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite		
00400	pH	P - See Comments	0	--	Sample					=	7.0			=	7.3	12 - SU	05/WK - Five Per Week	GR - Grab	
					Permit Req.						6.5 INST MIN				9.0 INST MAX	12 - SU	05/WK - Five Per Week	GR - Grab	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	219.0	=	210.2	=	26 - lb/d	=	3.1	=	3.0	19 - mg/L	02/07 - Twice Every Week	24 - 24 Hour Composite	
					Permit Req.						2125.0 MO AVG	<=	3183.0 WKLY AVG	26 - lb/d				02/07 - Twice Every Week	24 - 24 Hour Composite
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample					=	253.2				19 - mg/L	02/07 - Twice Every Week	24 - 24 Hour Composite		
					Permit Req.						Req Mon MO AVG				19 - mg/L	02/07 - Twice Every Week	24 - 24 Hour Composite		

Value NODI											
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	= 4.6	= 6.8	26 - lb/d	< 0.1	= 0.1	19 - mg/L
					Permit Req. Value NODI	<= 191.0 MO AVG	<= 633.0 DAILY MX	26 - lb/d	<= 2.7 MO AVG	<= 8.93 DAILY MX	19 - mg/L
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample				= 0.7	= 0.7	19 - mg/L
					Permit Req. Value NODI				Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample				= 21.2	= 21.2	19 - mg/L
					Permit Req. Value NODI				Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample				= 4.6	= 5.2	19 - mg/L
					Permit Req. Value NODI				Req Mon MO AVG	Req Mon WKLY AVG	19 - mg/L
00671	Phosphate, ortho, dissolved [as P]	1 - Effluent Gross	0	--	Sample				= 0.9	= 2.8	19 - mg/L
					Permit Req. Value NODI				Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L
00681	Carbon, dissolved organic [as C]	P - See Comments	0	--	Sample				= 5.4	= 5.4	19 - mg/L
					Permit Req. Value NODI				Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L
00900	Hardness, total [as CaCO3]	P - See Comments	0	--	Sample				= 165.9	= 165.9	19 - mg/L
					Permit Req. Value NODI				Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L
01119	Copper, total recoverable	P - See Comments	1	--	Sample				= 4.5	= 4.5	28 - ug/L
					Permit Req. Value NODI				Req Mon MO AVG	Req Mon DAILY MX	28 - ug/L
X 31648	E. coli, MTEC-MF	1 - Effluent Gross	0	--	Sample				= 6.1	= 1203.3	13 - #/100mL
					Permit Req. Value NODI				<= 126.0 MO GEOMN	<= 406.0 INST MAX	13 - #/100mL
45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	= 0.0	SP - N=0;Y=1				01/30 - Monthly VI - Visual
					Permit Req. Value NODI	<= 0.0 MO MAX	SP - N=0;Y=1				01/30 - Monthly VI - Visual
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	= 8.5	= 8.9	03 - MGD			99/99 - Continuous RC - Recorder (auto)
					Permit Req. Value NODI	Req Mon MO AVG	Req Mon DAILY MX	03 - MGD			99/99 - Continuous RC - Recorder (auto)
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample				= 98.0		23 - %
					Permit Req. Value NODI				>= 85.0 MO AV MN		23 - %
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample				= 98.8		23 - %
					Permit Req. Value NODI				>= 85.0 MO AV MN		23 - %

#### Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

#### Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge				
Code	Name									
31648	E. coli, MTEC-MF	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes				
<b>Comments</b> Please see the attachment with the explanation of the exceedance that was recorded for E-COLI.										
<b>Attachments</b>										
Name		Type	Size							
1.docx		docx	155948.0							
<b>Report Last Saved By</b> <b>CALDWELL, CITY OF</b>										
User:	DHARMON@CITYOFCALDWELL.ORG									
Name:	David Harmon									
E-Mail:	dharmon@cityofcaldwell.org									
Date/Time:	2025-12-19 10:09 (Time Zone: -07:00)									
<b>Report Last Signed By</b>										
User:	DHARMON@CITYOFCALDWELL.ORG									
Name:	David Harmon									
E-Mail:	dharmon@cityofcaldwell.org									
Date/Time:	2025-12-19 10:10 (Time Zone: -07:00)									