

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit	
Permit #: ID0021504	Permittee: CALDWELL, CITY OF
Major: Yes	Permittee Address: 621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605
Permitted Feature: 001 External Outfall	Discharge: 001-A Boise River
Facility: CALDWELL, CITY OF - CALDWELL WWTP	
Facility Location: 208 JOHNSON LANE CALDWELL, ID 83605	
Report Dates & Status	
Monitoring Period: From 02/01/26 to 02/28/26	DMR Due Date: 03/20/26
Status: NetDMR Validated	
Considerations for Form Completion	
P=Effluent, See Table 1, Note 10 for samples to be collected on the same day; Q=Effluent, full narrative description in Permit Part I.B.3.; R=Effluent, Table 1, note 7. Report Mo Inst Max, Max Daily Avg, 7 Day Running Avg of Daily Inst Max	
Principal Executive Officer	
First Name: Andrew	Title: Assistant Superintendent
Last Name: Abercrombie	Telephone: 208-504-9965
No Data Indicator (NODI)	
Form NODI: --	

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00010	Temperature, water deg. centigrade	R - See Comments	0	--	Sample	=	18.7	=	18.1	=	18.7	04 - deg C	0	99/99 - Continuous	RC - Recorder (auto)			
					Permit Req.		Req Mon MX DA AV		Req Mon MX 7D AV		Req Mon INST MAX	04 - deg C						
					Value NODI													
00094	Conductivity	P - See Comments	0	--	Sample	=	841.2	=	871.0	11 - umho/cm	0	01/30 - Monthly	24 - 24 Hour Composite					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	11 - umho/cm								
					Value NODI													
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	368.2	=	360.8	26 - lb/d	0	01/07 - Weekly	24 - 24 Hour Composite					
					Permit Req.	<=	2127.0 MO AVG	<=	3190.0 WKLY AVG	26 - lb/d				<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L
					Value NODI													
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample	=	231.2			19 - mg/L	0	01/07 - Weekly	24 - 24 Hour Composite					
					Permit Req.		Req Mon MO AVG		19 - mg/L									
					Value NODI													
00400	pH	P - See Comments	0	--	Sample	=	6.9			12 - SU	0	05/WK - Five Per Week	GR - Grab					
					Permit Req.	>=	6.5 INST MIN			<=				9.0 INST MAX	12 - SU			
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	382.0	=	383.5	26 - lb/d	0	02/07 - Twice Every Week	24 - 24 Hour Composite					
					Permit Req.	<=	2125.0 MO AVG	<=	3183.0 WKLY AVG	26 - lb/d				<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L
					Value NODI													
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	263.3			19 - mg/L	0	02/07 - Twice Every Week	24 - 24 Hour Composite					
					Permit Req.		Req Mon MO AVG		19 - mg/L									
					Value NODI													

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User: AABERCROMBIE@CITYOFCALDWELL.ORG
Name: Andrew Abercrombie
E-Mail: aabercrombie@cityofcaldwell.org
Date/Time: 2026-03-11 07:23 (Time Zone: -06:00)

Report Last Signed By

User: AABERCROMBIE@CITYOFCALDWELL.ORG
Name: Andrew Abercrombie
E-Mail: aabercrombie@cityofcaldwell.org
Date/Time: 2026-03-11 07:25 (Time Zone: -06:00)