



# Caldwell Rural Fire Protection District

621 Cleveland Blvd. Caldwell ID 83605  
Phone 208-455-3032 Fax 208-455-3014

## Inspection Requirements for Temporary Fireworks Stands

The following is a list of specific requirements that Applicants need to use to "pre-inspect" their stands for compliance. All items must be completed prior to the time of their scheduled fire inspection. Compliance with ALL of these will enhance your chances to pass your inspection the first time, allowing you to open sooner.

1. **Documentation from Canyon County that approves sales on the subject property**
2. Stands must be at least 25' away from any other building or structure.
3. Stands must be at least 100' away from any fuel storage / dispensing station.
4. Stands must meet all International Code requirements for a "temporary" stand.
5. Stands may not exceed 600 SF in floor area.
6. Exit doors must be located at *both ends* of the structure, be thirty inches (30") wide and must open outward. Exits must be unobstructed, clearly marked and accessible.
7. Stands must have two (2) fire extinguishers. One shall be a **2A** rated **water type extinguisher** and the other must be a **2A10BC** rated **multi-purpose** extinguisher. Extinguishers must have a current service tag dated within the past eleven months and must be mounted three to five feet above floor level. Extinguishers must be readily *visible* and *accessible* at all times. Extinguishers must not be blocked or used to hang things on.
8. The following signage is required to be posted on all interior and exterior sides of the stand: "FIREWORKS - NO SMOKING WITHIN 50 FEET" and "NO FIREWORKS TO BE DISCHARGED WITHIN 300 FEET". These signs are to be in red, block-style lettering, 4" tall and must be visible and in a legible condition at all times. **Signage must also be in Spanish.**
9. Stands must have at least one **metal** trash receptacle with a **securely-fitting lid** in place.
10. Exit paths must be clear and unobstructed, and must remain that way at all times.
11. Stands must be kept clean and free of empty boxes, paper or other debris or trash.
12. All ground underneath and for 30 feet around all fireworks stands must be cleared, and kept clear of any weeds, combustible vegetation or material and debris.
13. Motor vehicles or generators must be parked or kept at least twenty-five feet (25') away from the stand. **Sleeping in stands is prohibited.**
14. No bare light bulbs may be used in the stand, all lights must have guards/covers on them.
15. Exit signs (8" x 12") must be posted above or on each exit door.
16. Exits doors must open *outward* with minimal effort.
17. The "Permit to Operate" must be posted and visible to the public at all times.
18. No one under the influence of drugs or alcohol is allowed in the stand at any time.
19. Stands must be at least 100', but not less than 500', from a working fire hydrant.

**To schedule your fireworks stand inspection call Fire Prevention at 208.455.3032**  
**NO FIREWORKS STAND MAY SELL FIREWORKS UNTIL ALL REQUIREMENTS ARE MET.**

## **FIREWORKS SALES PERMIT APPLICATION**

***This form must be filed with the Fire Code Official of the Fire District at the  
Caldwell Fire Admin.  
621 Cleveland Blvd.  
Caldwell, Idaho 83605***

**Applicant:** Please set forth the name and address of the applicant (or the names of all partners, if a partnership, the name of the corporation and the corporate officers if a corporation, or the name of the limited liability company and all of its members, if a limited liability company). **A site inspection shall be required prior to the actual sale of fireworks.**

|                                 |  |
|---------------------------------|--|
| <b>Applicant Name:</b>          |  |
| <b>Current Mailing Address:</b> |  |
| <b>Phone Number:</b>            |  |
| <b>Fax:</b>                     |  |
| <b>E-mail address:</b>          |  |

**Location of Sales:** Please identify each exact location of the fireworks sales:

|                 |  |
|-----------------|--|
| Location No. 1: |  |
| Location No. 2: |  |
| Location No. 3: |  |
| Location No. 4: |  |
| Location No. 5: |  |

**Bond or Certificate of Public Liability Insurance:** Please attach the bond or valid certificate of public liability and property-casualty insurance providing coverage of up to ONE HUNDRED THOUSAND DOLLARS (\$100,000.00) for personal injury and property damage providing coverage at each location:

**Payment of Application Fee:** Applicant must pay a fee for issuing a permit under this Chapter of TWO HUNDRED AND FIFTY DOLLARS. (\$250.00).

**Additional Inspection or Enforcement Fee:** Applicant must pay a fee for inspection or non-compliance of requirements of the permit, additionally the permit may be revoked for violation of ONE HUNDRED AND TWENTY FIVE DOLLARS. (\$125.00)

**I verify that the above information supplied is true and correct:**

Signed: \_\_\_\_\_

Printed Name: \_\_\_\_\_

Date: \_\_\_\_\_

---

**OFFICIAL USE ONLY BELOW THIS LINE**

---

- ☐ Bond or Certificate provided with Application
- ☐ Application Fee Paid
- ☐ Information required has been provided and verified.

Received By: \_\_\_\_\_

Date: \_\_\_\_\_

Reviewed By: Fire Code Official

Date: \_\_\_\_\_

**Determination and Decision on Application:**

☐ **Permit Issued**

☐ **Denied**

When approval is given this application form also serves as a permit which shall be valid for twelve (12) months from the date of issuance and is nontransferable.

The permit herein issued shall be displayed in public view at the location listed on the permit.

Dated: \_\_\_\_\_

Signed \_\_\_\_\_

Caldwell Rural Fire Protection District  
Fire Code Official

---

**Notice of final action:** Please note that unless an appeal of this decision is filed with the Secretary of the District, within fourteen (14) days of date of service, this is a final action. Appeals will be heard by the Board of Commissioners of this District at an open meeting, as scheduled by the Commissioners of this District.

---

## FIREWORKS STORAGE INFORMATION

**Instructions:** Please supply all information requested. Use back of form if additional space is needed. Answer accurately, please print clearly and sign/date at the bottom.

STAND LOCATION: \_\_\_\_\_

ON-SITE MANAGER'S NAME: \_\_\_\_\_ AGE: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

PHONE 1: \_\_\_\_\_ PHONE 2: \_\_\_\_\_ DL# \_\_\_\_\_

### EMPLOYEES WORKING AT STAND (Must be 16 yrs. of age or older):

NAME: \_\_\_\_\_ AGE: \_\_\_\_\_

NAME: \_\_\_\_\_ AGE: \_\_\_\_\_

NAME: \_\_\_\_\_ AGE: \_\_\_\_\_

NAME: \_\_\_\_\_ AGE: \_\_\_\_\_

SUPPLIER: \_\_\_\_\_ PHONE: \_\_\_\_\_

LOCAL REP: \_\_\_\_\_ PHONE: \_\_\_\_\_

STORAGE INFO: When the stand is closed nightly, and before and after the sales period, please identify the physical location(s) of where fireworks will be stored:

\_\_\_\_\_

APPROVAL BY FIRE OFFICIAL FROM AHJ STORAGE LOCATION:

\_\_\_\_\_  
Fire Department Official

\_\_\_\_\_  
Fire Department or Agency

\_\_\_\_\_  
Fire Official's Signature

\_\_\_\_\_  
Fire Official's Phone Number

**I certify that the information supplied above is true and accurate to the best of my knowledge, and will promptly advise the CFD if any information changes.**

OPERATOR'S SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_\_

MISC. NOTES or SPECIAL CONDITIONS: