

DMR Copy of Record

Permit

Permit #:	ID0021504	Permittee:	CALDWELL, CITY OF	Facility:	CALDWELL, CITY OF - CALDWELL WWTP
Major:	Yes	Permittee Address:	621 E. CLEVELAND BLVD CALDWELL, ID 83605	Facility Location:	208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature:	REC External Outfall	Discharge:	REC-A Boise River, Upstream		

Report Dates & Status

Monitoring Period:	From 07/01/18 to 07/31/18	DMR Due Date:	08/20/18	Status:	NetDMR Validated
---------------------------	----------------------------------	----------------------	-----------------	----------------	-------------------------

Considerations for Form Completion

Permit Part I.E. lists samples to be taken on the same day.

Principal Executive Officer

First Name:		Title:		Telephone:	
Last Name:					

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
00010	Temperature, water deg. centigrade	5 - Upstream Monitoring	0	--	Sample						=	21.92	=	23.6	04 - deg C	99/99 - Continuous	RC - Recorder (auto)
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	04 - deg C		
					Value NODI												
00061	Stream flow, instantaneous	5 - Upstream Monitoring	0	--	Sample					=	263			08 - cfs	01/07 - Weekly	GR - GRAB	
					Permit Req.							Req Mon INST MIN					08 - cfs
					Value NODI												
00070	Turbidity	5 - Upstream Monitoring	0	--	Sample						=	23.8		43 - NTU	01/07 - Weekly	GR - GRAB	
					Permit Req.							Req Mon INST MAX		43 - NTU			
					Value NODI												
00300	Oxygen, dissolved [DO]	5 - Upstream Monitoring	0	--	Sample					=	8.07			19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.							Req Mon INST MIN					19 - mg/L
					Value NODI												
00310	BOD, 5-day, 20 deg. C	5 - Upstream Monitoring	0	--	Sample						=	3		19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.							Req Mon INST MAX		19 - mg/L			
					Value NODI												
00400	pH	5 - Upstream Monitoring	0	--	Sample					=	7.88			12 - SU	01/07 - Weekly	GR - GRAB	
					Permit Req.							Req Mon INST MIN		8.16			12 - SU
					Value NODI												
00600	Nitrogen, total [as N]	5 - Upstream Monitoring	0	--	Sample						=	21.7		19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.							Req Mon INST MAX		19 - mg/L			
					Value NODI												
00665	Phosphorus, total [as P]	5 - Upstream Monitoring	0	--	Sample						=	1.23		28 - ug/L	01/30 - Monthly	GR - GRAB	
					Permit Req.							Req Mon INST MAX		28 - ug/L			
					Value NODI												
32230	Chlorophyll A	5 - Upstream Monitoring	0	--	Sample						=	0.0011		28 - ug/L	01/30 - Monthly	GR - GRAB	
					Permit Req.							Req Mon INST MAX		28 - ug/L			
					Value NODI												

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
ALI_LETTER_DMR.pdf	pdf	15180

Report Last Saved By

CALDWELL, CITY OF

User: SARREOLA@CITYOFCALDWELL.ORG
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2018-08-21 08:15 (Time Zone: -06:00)

Report Last Signed By

User: SARREOLA@CITYOFCALDWELL.ORG
Name: Salvador Arreola
E-Mail: sarreola@cityofcaldwell.org
Date/Time: 2018-08-21 08:17 (Time Zone: -06:00)