

DMR Copy of Record

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	= 87.43	=	226.9	26 - lb/d			=	1.68	=	4.36	19 - mg/L		02/07 - Twice Every Week	24 - COMP24
					Permit Req.	Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d				Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		02/07 - Twice Every Week	24 - COMP24
					Value NODI														

Permit
Permit #: ID0021504 | **Permittee:** CALDWELL, CITY OF | **Facility:** CALDWELL, CITY OF - CALDWELL WWTP
Major: Yes | **Permittee Address:** 621 E. CLEVELAND BLVD CALDWELL, ID 83605 | **Facility Location:** 208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature: 001 External Outfall | **Discharge:** 001-C Boise River

Report Dates & Status
Monitoring Period: From 01/01/19 to 01/31/19 | **DMR Due Date:** 02/20/19 | **Status:** NetDMR Validated

Considerations for Form Completion

Principal Executive Officer
First Name: Brent | **Title:** Public Works Director | **Telephone:** 208-455-4678
Last Name: Orton

No Data Indicator (NODI)
Form NODI: --

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
CALDWELL, CITY OF
User: RKKEETON
Name: Kathryn Keeton
E-Mail: kkeeton@cityofcaldwell.org
Date/Time: 2019-02-19 09:55 (Time Zone: -07:00)

Report Last Signed By
User: SARREOLA@CITYOFCALDWELL.ORG
Name: Salvador Arreola
E-Mail: sarreola@cityofcaldwell.org
Date/Time: 2019-02-20 10:29 (Time Zone: -07:00)