

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Value NODI											
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	6.8	03 - MGD							99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Value NODI											
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		97.23							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		96.03							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
2019_02_WWTP_Lab_Statement.pdf	pdf	370602
2019_02_ALI_Lab_Statement.pdf	pdf	14166
2019_02_supporting_data.xlsx	xlsx	82883

Report Last Saved By

CALDWELL, CITY OF

User: RHENSON@CITYOFCALDWELL.ORG
 Name: Roy Henson
 E-Mail: rhenson@cityofcaldwell.org
 Date/Time: 2019-03-18 13:20 (Time Zone: -06:00)

Report Last Signed By

User: SARREOLA@CITYOFCALDWELL.ORG
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2019-03-18 14:14 (Time Zone: -06:00)