

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Value NODI											
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	7.47	03 - MGD							99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Value NODI											
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=				95.36			23 - %		01/30 - Monthly	CA - CALCTD
					Permit Req.	>=				85 MO AV MN			23 - %		01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=				86.67			23 - %		01/30 - Monthly	CA - CALCTD
					Permit Req.	>=				85 MO AV MN			23 - %		01/30 - Monthly	CA - CALCTD
					Value NODI											

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quantity or Loading Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
31648	E. coli, MTEC-MF	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes

Comments

Attachments

Name	Type	Size
2019_06_ALL_Lab_Statement.pdf	pdf	13757
2019_06_supporting_data.xlsx	xlsx	83735
2019_06_Lab_Statment_WWTP.docx	docx	1180918

Report Last Saved By

CALDWELL, CITY OF

User: RKKEETON
 Name: Kathryn Keeton
 E-Mail: kkeeton@cityofcaldwell.org
 Date/Time: 2019-07-22 10:52 (Time Zone: -06:00)

Report Last Signed By

User: SARREOLA@CITYOFCALDWELL.ORG
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2019-07-22 11:23 (Time Zone: -06:00)