

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Value NODI											
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	8.4	03 - MGD							99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Value NODI											
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		96.3							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		89.8							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	All	Soft	All permit limit values for the Parameter are missing sample values or NODI selection. (Error Code: -1)	Yes

Comments

Attachments

Name	Type	Size
2019_07_ALI_Lab_Statement.pdf	pdf	16063
2019_07_supporting_data.xlsx	xlsx	84713
Noncompliance_report_08_15_2019_Phosphorus_Signed.pdf	pdf	335411
2019_07_Lab_Statment_WWTP.pdf	pdf	371847

Report Last Saved By

CALDWELL, CITY OF

User: RKKEETON
 Name: Kathryn Keeton
 E-Mail: kkeeton@cityofcaldwell.org
 Date/Time: 2019-08-16 14:15 (Time Zone: -06:00)

Report Last Signed By

User: SARREOLA@CITYOFCALDWELL.ORG
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2019-08-21 08:37 (Time Zone: -06:00)