

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	8.71	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD								99/99 - Continuous	RC - Recorder (auto)
					Value NODI													
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		97.81									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		97.21									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
2019_9_ALI_Lab_Statement.pdf	pdf	20077
2019_09_Lab_Statement_WWTP.pdf	pdf	380549
2019_09_supporting_data.xlsx	xlsx	103783

Report Last Saved By

CALDWELL, CITY OF

User: RKKEETON
 Name: Kathryn Keeton
 E-Mail: kkeeton@cityofcaldwell.org
 Date/Time: 2019-10-15 11:55 (Time Zone: -06:00)

Report Last Signed By

User: SARREOLA@CITYOFCALDWELL.ORG
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2019-10-17 12:20 (Time Zone: -06:00)