



CITY OF
Caldwell, Idaho

GARRET NANCOLAS
Mayor

208.455.3011
(f) 208.455.3003

City Hall
411 Blaine Street
Caldwell, Idaho 83605

Post Office Box
P.O. Box 1179
Caldwell, Idaho 83606

For a list of the City
Council members, visit:
Website
www.cityofcaldwell.com

James Craft
Compliance Office
Idaho Department of Environmental Quality
Boise Regional Office 1445 North Orchard Street
Boise, Idaho 83706

June 19, 2020

Re: Regarding SSO reported on June 15th 2020

To whom this may concern,

On June 15th we received a call out for a sewer overflow at 1312 Paynter Avenue Caldwell, ID 83605. Sewage came up through the floor drains of the establishment, a rough estimate is 2100 gallons of wastewater. It turns out that there was a blockage of grease and root mass in the city line. Once it was cleared, it drained back into the main line. The business has filed a tort claim with the city and this letter is to stay within compliance within the five day written compliance notification process. A copy of the operators report and map is being submitted along with this letter.

Sincerely,
Sal Arreola
WWTP Superintendent

"The Treasure of the Valley"