


Safety Glazing:

1. Glazing adjacent to stairways within 60" horizontally of the bottom tread of the stairway in any direction when the exposed surface of the glazing is less than 60" above the nose of the tread.

Exceptions:

1. The side of the stairway has a guardrail or handrail including balusters or in-fill panels, complying with sections R311.7.6 and R312 and the plane of the glass is more than 18" from the railing; or
2. When a solid wall or panel extends from the plane of the adjacent walking surface to 34" to 36" above the walking surface and the construction at the top of the wall or panel is capable of withstanding the same horizontal load as a guard.

				
<i>Department of Building Safety</i>				
TITLE SAFETY GLAZING REQUIREMENTS AT STAIRWAYS				
SIZE	CAGE CODE	DWG NO	09-06	REV
208-455-3024				
SCALE	NTS	SHEET	1	
Fax: 208-455-3050				