

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1						01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1						01/30 - Monthly	VI - VISUAL
					Value NODI										
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	6.229	03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD					99/99 - Continuous	RC - Recorder (auto)
					Value NODI										
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		97						01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN						01/30 - Monthly	CA - CALCTD
					Value NODI										
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		96						01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN						01/30 - Monthly	CA - CALCTD
					Value NODI										

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
31648	E. coli, MTEC-MF	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes

Comments

Attachments

Name	Type	Size
2017_12_supporting_data.xlsx	xlsx	75607
2017_12_ALI_Lab_statement.pdf	pdf	17538
2017_12_UV_Power_Outage_Letter.pdf	pdf	150824
2017_12_Lab_Statement_WWTP.pdf	pdf	180443

Report Last Saved By

CALDWELL, CITY OF

User: rhawker@cityofcaldwell.org
 Name: Rodger Hawker
 E-Mail: rhawker@cityofcaldwell.org
 Date/Time: 2018-01-22 13:05 (Time Zone: -08:00)

Report Last Signed By

User: sarreola@cityofcaldwell.org
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2018-01-22 13:06 (Time Zone: -08:00)