

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Value NODI											
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	6.173	10.305	03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Value NODI											
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		97							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		96							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
2017_BRV_Report_Appendix_B.pdf	pdf	619992
2018_01_supporting_data.xlsx	xlsx	70140
2017_BRV_Report_Appendix_A.pdf	pdf	2897336
2018_01_Phosphorus_Removal_Update.docx	docx	1186733
2018_01_Lab_Statement_WWTP.pdf	pdf	51994
2017_Yearly_SW_Monitoring_Report.docx	docx	393939
2017_BRV_Report_Appendix_C.pdf	pdf	7003556
2018_Lab_Statement_ALI.pdf	pdf	18281

Report Last Saved By

CALDWELL, CITY OF

User: kchattin@cityofcaldwell.org
Name: Kaitlin Chattin
E-Mail: kchattin@cityofcaldwell.org
Date/Time: 2018-02-20 15:05 (Time Zone: -08:00)

Report Last Signed By

User: sarreola@cityofcaldwell.org
Name: Salvador Arreola
E-Mail: sarreola@cityofcaldwell.org
Date/Time: 2018-02-20 15:05 (Time Zone: -08:00)