



45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	6.629	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX 03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Value NODI													
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		98									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		98									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
2016_December_WETT_Retest_Wk_1.PDF	pdf	2075160
2016_December_WETT_Retest_Wk_2.PDF	pdf	2240704
2016_12_IDEQ_Placement_Log_2016.xlsx	xlsx	52105
2016_12_Lab_Statement.pdf	pdf	50128
2016_12_ALL_Lab_Statement.PDF	pdf	18662
2016_12_supporting_data.xlsx	xlsx	38511

**Report Last Saved By**

CALDWELL, CITY OF

User:	rhawker@cityofcaldwell.org	Date/Time:	2017-01-18 07:47 (Time Zone: -08:00)
Name:	Rodger Hawker		
E-Mail:	rhawker@cityofcaldwell.org		