

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	7.206	=	11.638	03 - MGD							99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	RC - Recorder (auto)
					Value NODI													
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=				98							01/30 - Monthly	CA - CALCTD
					Permit Req.					>=	85 MO AV MN						01/30 - Monthly	CA - CALCTD
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=				98							01/30 - Monthly	CA - CALCTD
					Permit Req.					>=	85 MO AV MN						01/30 - Monthly	CA - CALCTD
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
2017_01_24_City_of_Caldwell_WWTP_WET_Fleas.PDF	pdf	2128512
2017_01_20_lab_statement.docx	docx	1175161
2017_01_ALI_Letter.pdf	pdf	26538
2017_01_supporting_data.xlsx	xlsx	39013
Phosphorus_Removal_Written_Progress_Report.docx	docx	10902
2017_01_10_City_of_Caldwell_WWTP_WET.pdf	pdf	3220414

Report Last Saved By

CALDWELL, CITY OF

User:	rhawker@cityofcaldwell.org	Date/Time:	2017-02-20 13:26 (Time Zone: -08:00)
Name:	Rodger Hawker		
E-Mail:	rhawker@cityofcaldwell.org		