

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1						01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1						01/30 - Monthly	VI - VISUAL
					Value NODI										
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	9.002	03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX 03 - MGD						99/99 - Continuous	RC - Recorder (auto)
					Value NODI										
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		97						01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN						01/30 - Monthly	CA - CALCTD
					Value NODI										
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		98						01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN						01/30 - Monthly	CA - CALCTD
					Value NODI										

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
2017_03_supporting_data.xlsx	xlsx	196970
2017_03_ALL_Lab_Statement.PDF	pdf	18352
2017_1st_QTR_Boise_River.xlsx	xlsx	12200
2017_03_Lab_Statement_WWTP.pdf	pdf	659506

Report Last Saved By

CALDWELL, CITY OF

User:	rhawker@cityofcaldwell.org	Date/Time:	2017-04-20 14:50 (Time Zone: -07:00)
Name:	Rodger Hawker		
E-Mail:	rhawker@cityofcaldwell.org		