



45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Value NODI											
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	9.333	03 - MGD							99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX 03 - MGD							99/99 - Continuous	RC - Recorder (auto)
					Value NODI											
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		97							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		97							01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN							01/30 - Monthly	CA - CALCTD
					Value NODI											

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
2017_04_supporting_data.xlsx	xlsx	46012
2017_03_Operation_and_Maint_Plan_Satement.pdf	pdf	161493
2017_04_Lab_Statement_WWTP.pdf	pdf	237424
2017_04_ALI_Letter.PDF	pdf	18789

**Report Last Saved By**

CALDWELL, CITY OF

User:	sarreola@cityofcaldwell.org	Date/Time:	2017-05-24 16:02 (Time Zone: -07:00)
Name:	Salvador Arreola		
E-Mail:	sarreola@cityofcaldwell.org		