

DMR Copy of Record

Permit

Permit #:	ID0021504	Permittee:	CALDWELL, CITY OF	Facility:	CALDWELL, CITY OF - CALDWELL WWTP
Major:	Yes	Permittee Address:	621 E. CLEVELAND BLVD CALDWELL, ID 83605	Facility Location:	208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature:	001 External Outfall	Discharge:	001-D Boise River		

Report Dates & Status

Monitoring Period:	From 01/01/18 to 03/31/18	DMR Due Date:	04/20/18	Status:	NetDMR Validated
--------------------	----------------------------------	---------------	-----------------	---------	-------------------------

Considerations for Form Completion

Q=Effluent, sampling required monthly if target value exceeded; Permit Part I.B.10

Principal Executive Officer

First Name:	Brent	Title:	Public Works Director	Telephone:	208-455-4678
Last Name:	Orton				

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Sample Permit Req. Value NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
71901	Mercury, total recoverable	Q - See Comments	0	--								=	0.0016	=	0.0018	28 - ug/L	01/90 - Quarterly	24 - COMP24
													Req Mon MO AVG		Req Mon DAILY MX	28 - ug/L	01/90 - Quarterly	24 - COMP24

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User: rhawker@cityofcaldwell.org
 Name: Rodger Hawker
 E-Mail: rhawker@cityofcaldwell.org
 Date/Time: 2018-04-23 07:46 (Time Zone: -07:00)

Report Last Signed By

User: sarreola@cityofcaldwell.org
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2018-04-23 07:46 (Time Zone: -07:00)