

DMR Copy of Record

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	= 267.36	=	400.15	26 - lb/d			=	4.15	=	6.22	19 - mg/L		02/07 - Twice Every Week	24 - COMP24
					Permit Req.	Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d				Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		02/07 - Twice Every Week	24 - COMP24
					Value NODI														

Permit
Permit #: ID0021504 | **Permittee:** CALDWELL, CITY OF | **Facility:** CALDWELL, CITY OF - CALDWELL WWTP
Major: Yes | **Permittee Address:** 621 E. CLEVELAND BLVD CALDWELL, ID 83605 | **Facility Location:** 208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature: 001 External Outfall | **Discharge:** 001-C Boise River

Report Dates & Status
Monitoring Period: From 06/01/18 to 06/30/18 | **DMR Due Date:** 07/20/18 | **Status:** NetDMR Validated

Considerations for Form Completion

Principal Executive Officer
First Name: Brent | **Title:** Public Works Director | **Telephone:**
Last Name: Orton

No Data Indicator (NODI)
Form NODI: --

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
CALDWELL, CITY OF
User: KCHATTIN@CITYOFCALDWELL.ORG
Name: Kaitlin Chattin
E-Mail: kchattin@cityofcaldwell.org
Date/Time: 2018-07-20 13:59 (Time Zone: -06:00)

Report Last Signed By
User: SARREOLA@CITYOFCALDWELL.ORG
Name: Salvador Arreola
E-Mail: sarreola@cityofcaldwell.org
Date/Time: 2018-07-20 14:00 (Time Zone: -06:00)